



**Brighton & Hove
City Council**

PLANNING COMMITTEE ADDENDUM

2.00PM, WEDNESDAY, 16 MAY 2012

COUNCIL CHAMBER, HOVE TOWN HALL

ADDENDUM

ITEM Late Representations List

Page

Page	Site Address	Application No.	Update
83	Glebe Villas Playing Fields, Chelston Avenue, Hove	BH2012/00248	<p>Environmental Health comment that there have been no noise complaints and that proposed pavilion is very similar to the existing pavilion with a comparative, if not, improved impact on adjacent properties.</p> <p>Additionally, the location of the pavilion is on a playing field where some noise from play and sporting events should be expected. The scheme does include a heat recovery system and also a small plant room and may result in a noise impact.</p> <p>No <u>objection</u> is raised subject to the following condition:</p> <p>Additional condition:</p> <p>5. Noise associated with plant and machinery incorporated into the development shall be controlled such that the Rating Level, measured or calculated at 1-metre from the façade of the nearest existing noise sensitive premises, shall not exceed a level 5db below the existing LA90 background noise level. Rating Level and existing background noise levels to be determined as per the guidance provided in BS 4142:1997. In addition, there should be no significant low frequency tones present.</p> <p>Reason: To safeguard the amenities of the occupiers of adjoining properties and to comply with policy QD27 of the Brighton & Hove Local Plan.</p> <p>An additional letter has been received from 15 Glebe Villas withdrawing their original <u>objection</u> to the proposal subject to the scheme not resulting in a detrimental impact in terms of children being dropped off and picked up.</p>

NB. Representations received after midday the Friday before the date of the Committee meeting will not be reported (Sub-Committee resolution of 23 February 2005).

