FOUNDRY

Note:

Fire Extinguishers installed to BS5306 Fire Alarm installed to L2 – Automatic fire detection in escape routes, rooms leading onto escape routes and areas of high fire risk

CCTV – Installed internal and external Door Access – Electronic Door Access system installed

General Notes LEGEND Primary Escape Route Secondary Escape Route Fire Extinguisher Set 1 x 2kg CO2 1 x 6ltr Water Area of Licence Evac Plan/Licence Suite 9, The Cloisters Broyle Place Farm Laughton Road BN8 5SD **FOUNDRY** Hove Licence Plan 1 of 1 24/07/25 **VERSION 1** NOT TO SCALE

